

Richmond Water Resources Department
VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS Month **Jun-24**

Date	Meter	gallons produced	Finished Water Entering System		
			FL Lev	Entry Point Free CL2	PH Out
Sample Location			Waterhouse Tap	Waterhouse Tap	Waterhouse Tap
Target Range			0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0
May 31 #->	40,961,600				
1	40,979,600	18,000	0.80	1.02	7.34
2	41,087,900	108,300	0.80	0.98	7.33
3	41,113,500	25,600	0.80	0.89	7.31
4	41,209,400	95,900	0.70	0.88	7.28
5	41,272,700	63,300	0.70	1.08	7.29
6	41,272,700	0	0.80	0.87	7.26
7	41,413,900	141,200	0.80	0.82	7.31
8	41,413,900	0	0.80	0.89	7.31
9	41,501,300	87,400	0.80	0.90	7.33
10	41,501,300	0	0.80	1.01	7.34
11	41,608,000	106,700	0.80	1.26	7.35
12	41,628,400	20,400	0.70	1.06	7.33
13	41,730,300	101,900	0.80	1.10	7.31
14	41,808,400	78,100	0.70	1.01	7.30
15	41,909,500	101,100	0.70	1.21	7.37
16	41,980,100	70,600	0.80	1.10	7.36
17	42,067,300	87,200	0.70	1.19	7.34
18	42,129,100	61,800	0.70	1.15	7.27
19	42,211,500	82,400	0.70	0.94	7.27
20	42,245,700	34,200	0.80	1.30	7.27
21	42,339,500	93,800	0.70	1.09	7.27
22	42,353,500	14,000	0.70	1.23	7.31
23	42,434,800	81,300	0.70	1.33	7.32
24	42,458,800	24,000	0.70	1.05	7.30
25	42,509,500	50,700	0.70	1.07	7.28
26	42,562,500	53,000	0.70	1.16	7.30
27	42,612,800	50,300	0.80	1.20	7.33
28	42,664,400	51,600	0.70	1.18	7.37
29	42,707,900	43,500	0.70	1.05	7.36
30	42,779,800	71,900	0.70	1.05	7.29
Total		1,818,200			
Ave.		58,652	0.74	1.07	7.31
Max.		141,200	0.80	1.33	7.37
Min		0	0.70	0.82	7.26

Vermont Monthly Operations Report For Groundwater Systems
And Systems Purchasing Groundwater

June

2024

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326

A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.


See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature  Date 7/1/24

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature  Date 7/1/24

Notes:
