

Richmond Water Resources Department
VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS Month **Aug-24**

Date	Meter	gallons produced	Finished Water Entering System			Weekly Endyne FI Results
			FL Lev	Entry Point Free CL2	PH Out	
Sample Location			Waterhouse Tap	Waterhouse Tap	Waterhouse Tap	
Target Range			0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0	
July 31 #->	44,406,900					
1	44,406,900	0	1.00	0.99	7.32	0.8
2	44,522,400	115,500	0.80	0.95	7.31	
3	44,528,500	6,100	0.80	0.84	7.33	
4	44,625,300	96,800	0.80	1.08	7.33	
5	44,625,300	0	0.90	0.88	7.39	
6	44,719,100	93,800	0.90	1.09	7.36	0.75
7	44,739,600	20,500	0.80	1.03	7.37	
8	44,817,600	78,000	0.80	1.10	7.35	
9	44,854,800	37,200	0.80	1.06	7.35	
10	44,915,900	61,100	0.90	0.94	7.30	
11	44,948,700	32,800	0.80	0.82	7.34	
12	45,017,600	68,900	0.80	0.82	7.38	
13	45,031,200	13,600	0.80	1.29	7.42	
14	45,124,100	92,900	0.80	1.46	7.39	0.7
15	45,152,300	28,200	0.80	1.35	7.36	
16	45,244,800	92,500	0.80	1.32	7.36	
17	45,270,300	25,500	0.70	1.29	7.36	
18	45,353,800	83,500	0.90	1.34	7.39	
19	45,369,100	15,300	0.80	1.29	7.38	
20	45,435,600	66,500	0.80	1.32	7.40	0.68
21	45,477,900	42,300	0.80	1.20	7.39	
22	45,529,900	52,000	0.80	1.37	7.37	
23	45,576,600	46,700	0.70	1.24	7.35	
24	45,646,300	69,700	0.70	1.27	7.37	
25	45,697,800	51,500	0.80	1.16	7.37	
26	45,741,600	43,800	0.80	1.22	7.36	
27	45,792,500	50,900	0.80	1.34	7.40	
28	45,892,700	100,200	0.90	1.51	7.40	
29	45,913,600	20,900	0.90	1.36	7.45	
30	46,004,300	90,700	0.80	1.20	7.40	
31	46,062,000	57,700	0.80	0.94	7.38	
Total		1,655,100				
Ave.		53,390	0.82	1.16	7.37	
Max.		115,500	1.00	1.51	7.45	
Min		0	0.70	0.82	7.30	

Vermont Monthly Operations Report For Groundwater Systems
And Systems Purchasing Groundwater

August

2024

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326


A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.

See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature  Date 9/3/24

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature  Date 9/3/24

Notes:
