

Date: March 9, 2020

William Zabiloski
Regional Engineer
Drinking Water and Groundwater Protection Division
111 West Street
Essex Junction, VT 05452

RE: Peaceable Kingdom Project, Richmond, Vermont
Wastewater System and Potable Water Supply Permit #WW-4-4214-2
Construction statement for Footprint Units #1 & #2

Dear Bill:

We are writing on behalf of Gary Bressor of Peaceable Kingdom, LLC regarding construction of the building sewer service serving the building with two footprint lot units (1 & 2) shown on plans approved in WW-4-4214-2 of the Peaceable Kingdom Subdivision on Thompson Road in the Town of Richmond. A new 4" building sewer service was constructed starting from an existing 6" service stub installed previously when the sewer collection system along Thompson Road was constructed. A new 6" x 4" wye was installed on the stub, and a new 4" SDR 35 PVC pipe was installed to the building, then under the foundation, and then connected to new interior wastewater piping. This differs from the plans only in the size of the new service, which was shown as a 6" pipe.

As required by conditions of the Permit, we certify that the installation related information submitted is true and correct, and that, in the exercise of our reasonable professional judgement, the wastewater service as described above has been installed substantially in accordance with the permitted design (except as noted above) and all permit conditions, was inspected, was properly tested, and has successfully met those performance tests.

Please call our office with any questions. Please note that the sewer service to unit #3, and the proposed manhole shown on the plans in this location of the site have not been constructed. We understand a permit amendment has been applied for, and the manhole is proposed to be replaced with a cleanout.

Sincerely,

 Spence Excavating & Construction
CONTRACTOR NAME and COMPANY NAME

c: Gary Bressor