

Richmond Water Resources Department

VERMONT GROUNDWATER SYSTEM #5084 DAILY TEST RESULTS Month

Feb-25

		Finished Water Entering System			Endyne FL Result	
Date	Meter	gallons produced	FL Lev	Entry Point Free CL2	PH Out	On Date Sampled
Sample Location			Waterhouse Tap	Waterhouse Tap	Waterhouse Tap	From The
Target Range			0.6 - 1.0 mg/L	0.8 - 4.0 mg/L	Minimum of 7.0	0.6-1.0 mg/L
January 31 #	4,457,500					
1	4,569,600	112,100	1.04	0.75	7.65	
2	4,569,600	0	1.11	0.72	7.66	
3	4,669,900	100,300	1.03	0.85	7.64	0.85
4	4,696,400	26,500	0.99	0.60	7.62	
5	4,731,600	35,200	0.99	0.80	7.65	
6	4,832,300	100,700	0.93	0.82	7.69	
7	4,832,300	0	0.93	0.76	7.68	
8	4,948,400	116,100	1.08	0.71	7.66	
9	4,948,400	0	1.00	0.54	7.66	
10	5,032,100	83,700	1.04	0.64	7.66	0.85
11	5,084,500	52,400	1.01	0.62	7.66	
12	5,122,100	37,600	1.09	0.85	7.66	
13	5,207,100	85,000	1.07	0.77	7.67	
14	5,207,100	0	0.94	0.72	7.69	
15	5,321,700	114,600	1.04	0.86	7.69	
16	5,321,700	0	1.05	0.78	7.70	
17	5,409,900	88,200	1.09	0.81	7.68	
18	5,435,200	25,300	1.03	0.70	7.67	0.81
19	5,498,200	63,000	0.94	0.75	7.64	
20	5,570,700	72,500	1.00	0.79	7.66	
21	5,596,300	25,600	1.09	0.72	7.67	
22	5,696,200	99,900	0.84	0.82	7.70	
23	5,696,200	0	0.76	0.80	7.70	
24	5,795,600	99,400	0.90	0.86	7.65	
25	5,829,500	33,900	0.84	0.92	7.64	
26	5,885,600	56,100	0.89	0.84	7.63	0.68
27	5,943,800	58,200	0.75	0.87	7.65	
28	5,943,800	0	0.81	0.78	7.66	
Total		1,486,300				
Ave.		47,945	0.97	0.77	7.66	0.7975
Max.		116,100	1.11	0.92	7.70	0.85
Min		0	0.75	0.54	7.62	0.68

Vermont Monthly Operations Report For Groundwater Systems
And Systems Purchasing Groundwater

FEB.

2025

Name of System: Richmond Water Resources Department

WSID # : 5084 Town : Richmond

Brad Snow Operator, Phone work--> 434 - 2178 Phone home--> 316-2326


A master meter is installed and functioning which records daily production

All water quality compliance analysis results have been reported to the Water Supply Division.

See attached for production information and results of daily parameter testing.

I certify, as the owner or authorized representative of this Water System, that I have completed this form, or reviewed it if completed by another, and that I have taken the necessary steps to ensure the information shown is correct. In making this certification, I understand that civil and/or criminal penalties may be imposed for submitting false information.

Prepared by Brad Snow, Class 3 Public Water System Operator # OP05111

Signature  Date 3/3/25

Approved by Josh Arneson, Richmond Town Manager and Authorized Representative

Signature  Date 3/14/25

Notes:
